



Jacqueline Foushee, P.E., C.M.E.  
Director  
City Engineer

**City of Rahway**  
**Department of Community Development**  
**Property Maintenance Division**  
One City Hall Plaza  
Rahway, NJ 07065

Phone: (732) 827-2176  
Fax: (732) 574-0477

[propertymaintenance@cityofrahway.com](mailto:propertymaintenance@cityofrahway.com)

## **Certificate of Occupancy - Fire Safety Requirements**

**The following lists are provided so that applicants can prepare for the Fire Safety inspection required to obtain a Certificate of Occupancy.**

### **SMOKE ALARM REQUIREMENTS**

- √ At minimum, one smoke alarm must be installed on every level of the home, including basements. A separate floor level is considered when three or more steps are between it.
- √ Smoke alarms shall be located no further than 10 feet from the bedroom doors.
- √ Smoke alarms in the basement should be installed on the ceiling/beam at the base of the stairs.
- √ Finished loft/attic space that can be used as livable space must have smoke alarm
- √ Battery operated smoke alarms must have a
- √ Ten-year Sealed Battery
- √ Existing hard-wired alarms cannot be replaced with battery types.
- √ Smoke alarms shall not be more than 10 years old

### **CARBON MONOXIDE ALARM REQUIREMENTS**

- √ Carbon monoxide alarms shall be installed within 10 feet from any sleeping area.
- √ Alarms shall be either in the common area between sleeping areas OR in all bedrooms.
- √ Existing hardwired alarms cannot be replaced with battery types.
- √ Sleeping areas are considered when a closet and heating device are present.

### **FIRE EXTINGUISHER REQUIREMENTS**

- √ One fire extinguisher is required for ALL residential dwellings
- √ Fire Extinguishers shall have a minimum rating of 2A:10BC and no more than 10 pounds
- √ Extinguisher must be visible and in a readily accessible location no more than 10 feet from the kitchen.
- √ Extinguishers may not be more than 12 years old.
- √ Extinguishers must be listed, labeled, charged and operable.